

WATER BYELAWS SCHEME

Our Ref: MVK/9207516/SJA.2721

21 December 1992

Chemco International Ltd
Units 3A-3B
East Shawhead Industrial Estate
Coatbridge
Scotland
M15 4LY

WRc

EVALUATION
& TESTING

C E N T R E

Dear Sir

WATER BYELAWS SCHEME

"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"

Referring to your application for the material(s) described below to be approved: from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf)

COATINGS, PAINTS AND LININGS - SITE APPLIED - MULTI-PURPOSE 5048

Chemco Protective Coating CC200. Glassflake re-inforced polyester resin, anti-corrosion coating. Mix and apply as per the manufacturer's instructions. Cure 21 days at 7°C. Cold water applications only.
Test Report: AL 106417/M.

9207516


Chemco International Ltd.

An entry, as above, will accordingly be included in the Water Fittings and Materials Directory, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings and Materials Directory: this may be abbreviated to "Listed by the Water Byelaws Scheme", or "Water Byelaws Scheme - Approved Product".

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in July 1997.

Yours faithfully




G D Mays
Manager, Water Byelaws Scheme

WRc EVALUATION & TESTING CENTRE, 660 AJAX AVENUE, SLOUGH, BERKSHIRE SL14BG
TELEPHONE: (0753) 537277. TELEX: 449541. FAX: (0753) 518323.

WRc p.l.c. Registered in England No. 2262098. Registered Office: Henley Road, Medmenham, PO. Box 16 Marlow, Buckinghamshire SL7 2HD England





MATERIALS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY
AND ARE USED IN THE MANUFACTURE OF WATER FITTINGS AND WATER
INSTALLATIONS AND IN THEIR ASSEMBLY, CONNECTION, DISCONNECTION
AND REPAIR

The material or product referred to in this letter is suitable for contact with, and for the manufacture of components of water fittings for use in contact with water for domestic purposes. The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use. Certain products are approved in the full knowledge that for many plastic materials and natural and synthetic rubbers, variations in curing times and temperatures may have a significant effect on water quality. The right is reserved to require the testing of components made from any of these materials before listing those components if it has any reason to believe that they differ from the materials originally tested and listed.

Entries in the Directory relating to components made from listed materials are included on the understanding that the components are made of precisely the same materials as the test samples without any modification and without the addition or substitution of any ingredients, and that, as applicable, the curing times and temperatures shall be as nearly as possible those recommended by the manufacturers of the materials or products and used for the production of test samples.

In order to avoid their affecting water quality materials must be allowed to cure at the correct temperature for the necessary length of time. This cannot always be achieved where materials are mixed on site, often in approximate proportions, and cured in situ often under cold, ill-ventilated conditions. Entries relating to products or materials in the Directory apply to materials or products produced under properly controlled factory conditions, and cannot be guaranteed to apply to site conditions.